


Casename **Case 74**

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low Ind | 18.8 | 61% | High x4 / Low x2 | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.62 | 72.71 | 1884 | 62.32% |
| S.D. | 0.29 | 0.51 | 345 | 2.56% |
| Max. | 23.56 | 74.41 | 2633 | 67.44% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.99 | 1.91 | 2.94 | 4.53 | 6.72 | 9.53 | 13.46 | 17.65 | 22.68 | 28.03 |
| Max. | 1.38 | 2.66 | 4.11 | 6.33 | 9.39 | 13.31 | 18.81 | 24.66 | 31.69 | 39.17 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.09 | 69.96 | 48 | 52.74% |
| S.D. | 0.31 | 0.56 | 22 | |
| Max. | 22.37 | 72.26 | 247 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.02 | 0.05 | 0.07 | 0.11 | 0.17 | 0.24 | 0.34 | 0.45 | 0.57 | 0.71 |
| Max. | 0.13 | 0.25 | 0.39 | 0.59 | 0.88 | 1.25 | 1.77 | 2.32 | 2.98 | 3.68 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 411 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1888 |
| 5 | 785000 | 2800 |
| 6 | 785000 | 3969 |
| 7 | 785000 | 5609 |
| 8 | 785000 | 7353 |
| 9 | 785000 | 9447 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 75

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|---------------------|
| Radial | 18.8 | 61% | Ceiling/Low 50/50 | 22 | 50% |
| Change Station | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation |
| ON alt design | On wall | Single | 1050 | 21000 gr | neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.88 | 71.38 | 1839 | 64.89% |
| S.D. | 0.19 | 0.34 | 362 | 2.56% |
| Max. | 22.31 | 72.15 | 2622 | 69.92% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.97 | 1.86 | 2.87 | 4.98 | 8.01 | 11.70 | 17.24 | 21.79 | 26.73 | 30.30 |
| Max. | 1.39 | 2.65 | 4.09 | 7.10 | 11.42 | 16.69 | 24.58 | 31.06 | 38.11 | 43.20 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.09 | 69.96 | 48 | 52.74% |
| S.D. | 0.31 | 0.56 | 22 | |
| Max. | 22.37 | 72.26 | 247 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.03 | 0.05 | 0.07 | 0.13 | 0.21 | 0.30 | 0.45 | 0.57 | 0.69 | 0.79 |
| Max. | 0.13 | 0.25 | 0.39 | 0.67 | 1.08 | 1.57 | 2.32 | 2.93 | 3.60 | 4.07 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 415 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2127 |
| 5 | 785000 | 3420 |
| 6 | 785000 | 4996 |
| 7 | 785000 | 7360 |
| 8 | 785000 | 9300 |
| 9 | 785000 | 11410 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 76

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|---------------------|
| Radial | 18.8 | 61% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation |
| | On wall | Single | 1050 | 21000 gr | neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.13 | 71.83 | 1857 | 64.05% |
| S.D. | 0.18 | 0.32 | 302 | 2.32% |
| Max. | 22.89 | 73.21 | 2435 | 68.79% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.98 | 1.88 | 2.90 | 4.85 | 7.61 | 11.03 | 16.07 | 20.51 | 25.49 | 29.63 |
| Max. | 1.28 | 2.46 | 3.80 | 6.36 | 9.98 | 14.46 | 21.07 | 26.89 | 33.42 | 38.85 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.39 | 68.71 | 55 | 55.19% |
| S.D. | 0.19 | 0.35 | 27 | |
| Max. | 21.23 | 70.21 | 236 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.03 | 0.06 | 0.09 | 0.14 | 0.23 | 0.33 | 0.48 | 0.61 | 0.76 | 0.88 |
| Max. | 0.12 | 0.24 | 0.37 | 0.62 | 0.97 | 1.40 | 2.04 | 2.61 | 3.24 | 3.77 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 414 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2049 |
| 5 | 785000 | 3218 |
| 6 | 785000 | 4662 |
| 7 | 785000 | 6791 |
| 8 | 785000 | 8667 |
| 9 | 785000 | 10772 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 77

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Slot | 18.8 | 61% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.14 | 71.86 | 1881 | 64.17% |
| S.D. | 0.26 | 0.46 | 351 | 2.58% |
| Max. | 22.90 | 73.22 | 2652 | 70.61% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.99 | 1.90 | 2.93 | 4.94 | 7.78 | 11.29 | 16.47 | 20.98 | 26.03 | 30.15 |
| Max. | 1.40 | 2.68 | 4.14 | 6.96 | 10.97 | 15.91 | 23.22 | 29.59 | 36.70 | 42.51 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.39 | 68.70 | 50 | 55.16% |
| S.D. | 0.23 | 0.42 | 21 | |
| Max. | 21.44 | 70.59 | 191 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.03 | 0.05 | 0.08 | 0.13 | 0.21 | 0.30 | 0.44 | 0.56 | 0.70 | 0.81 |
| Max. | 0.10 | 0.19 | 0.30 | 0.50 | 0.79 | 1.14 | 1.67 | 2.13 | 2.64 | 3.06 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 414 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2060 |
| 5 | 785000 | 3247 |
| 6 | 785000 | 4710 |
| 7 | 785000 | 6872 |
| 8 | 785000 | 8758 |
| 9 | 785000 | 10864 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 78

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low Ind | 18.8 | 61% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.09 | 71.76 | 1919 | 64.69% |
| S.D. | 0.22 | 0.40 | 362 | 2.65% |
| Max. | 22.67 | 72.81 | 2625 | 70.05% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 1.01 | 1.94 | 2.99 | 5.16 | 8.25 | 12.03 | 17.67 | 22.38 | 27.54 | 31.38 |
| Max. | 1.39 | 2.66 | 4.10 | 7.05 | 11.28 | 16.45 | 24.17 | 30.61 | 37.66 | 42.92 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.41 | 68.74 | 55 | 55.13% |
| S.D. | 0.24 | 0.44 | 20 | |
| Max. | 22.13 | 71.84 | 212 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.03 | 0.06 | 0.09 | 0.15 | 0.24 | 0.35 | 0.51 | 0.64 | 0.79 | 0.90 |
| Max. | 0.11 | 0.21 | 0.33 | 0.57 | 0.91 | 1.33 | 1.95 | 2.47 | 3.04 | 3.46 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 415 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2109 |
| 5 | 785000 | 3373 |
| 6 | 785000 | 4919 |
| 7 | 785000 | 7229 |
| 8 | 785000 | 9154 |
| 9 | 785000 | 11263 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 79

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Radial | 18.8 | 61% | 2 Door exhausts | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 23.12 | 73.62 | 1647 | 58.59% |
| S.D. | 0.37 | 0.66 | 301 | 2.52% |
| Max. | 24.34 | 75.81 | 2355 | 63.76% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.86 | 1.67 | 2.57 | 3.70 | 5.21 | 7.22 | 9.88 | 13.33 | 17.71 | 23.15 |
| Max. | 1.22 | 2.38 | 3.67 | 5.30 | 7.45 | 10.33 | 14.13 | 19.07 | 25.32 | 33.10 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.94 | 71.49 | 81 | 50.26% |
| S.D. | 0.36 | 0.64 | 26 | |
| Max. | 22.89 | 73.20 | 195 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.04 | 0.08 | 0.13 | 0.18 | 0.26 | 0.36 | 0.49 | 0.66 | 0.87 | 1.14 |
| Max. | 0.10 | 0.20 | 0.30 | 0.44 | 0.62 | 0.86 | 1.17 | 1.58 | 2.10 | 2.74 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution

Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----------|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 80

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Slot | 18.8 | 61% | 2 Door exhausts | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 23.22 | 73.80 | 1707 | 58.68% |
| S.D. | 0.44 | 0.79 | 311 | 2.60% |
| Max. | 24.40 | 75.91 | 2688 | 64.90% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.89 | 1.73 | 2.66 | 3.84 | 5.40 | 7.49 | 10.24 | 13.82 | 18.35 | 23.99 |
| Max. | 1.40 | 2.72 | 4.19 | 6.05 | 8.50 | 11.79 | 16.14 | 21.77 | 28.91 | 37.79 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.10 | 71.77 | 90 | 49.83% |
| S.D. | 0.43 | 0.78 | 22 | |
| Max. | 23.07 | 73.52 | 207 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.05 | 0.09 | 0.14 | 0.20 | 0.29 | 0.40 | 0.54 | 0.73 | 0.97 | 1.27 |
| Max. | 0.11 | 0.21 | 0.32 | 0.47 | 0.65 | 0.91 | 1.24 | 1.68 | 2.23 | 2.91 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 81

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low Ind | 18.8 | 61% | 2 Door exhausts | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 23.40 | 74.13 | 1741 | 58.28% |
| S.D. | 0.48 | 0.86 | 293 | 2.45% |
| Max. | 24.45 | 76.00 | 2720 | 63.62% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.91 | 1.76 | 2.72 | 3.92 | 5.51 | 7.64 | 10.45 | 14.10 | 18.72 | 24.47 |
| Max. | 1.41 | 2.75 | 4.24 | 6.12 | 8.60 | 11.93 | 16.33 | 22.03 | 29.25 | 38.24 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.45 | 72.41 | 89 | 48.73% |
| S.D. | 0.55 | 0.99 | 30 | |
| Max. | 23.36 | 74.05 | 278 | |

Room Breathing Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.05 | 0.09 | 0.14 | 0.20 | 0.28 | 0.39 | 0.54 | 0.72 | 0.96 | 1.25 |
| Max. | 0.14 | 0.28 | 0.43 | 0.63 | 0.88 | 1.22 | 1.67 | 2.25 | 2.99 | 3.91 |


Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution

Contamination conversion factors (kg/kg - 7 ppm)



| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 82

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Radial | 18.8 | 61% | 2 Door exhausts | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.29 | 72.13 | 1667 | 61.88% |
| S.D. | 0.53 | 0.96 | 419 | 3.59% |
| Max. | 23.63 | 74.53 | 2794 | 68.39% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.87 | 1.69 | 2.60 | 3.92 | 5.72 | 8.06 | 11.28 | 14.91 | 19.35 | 24.34 |
| Max. | 1.46 | 2.83 | 4.36 | 6.58 | 9.59 | 13.51 | 18.91 | 25.00 | 32.45 | 40.81 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.26 | 70.27 | 116 | 52.75% |
| S.D. | 0.91 | 1.64 | 53 | |
| Max. | 27.19 | 80.94 | 332 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.06 | 0.12 | 0.18 | 0.27 | 0.40 | 0.56 | 0.79 | 1.04 | 1.35 | 1.70 |
| Max. | 0.17 | 0.34 | 0.52 | 0.78 | 1.14 | 1.61 | 2.25 | 2.97 | 3.86 | 4.86 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution

Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----------|-----------------|-----------------|
| 1 | 785000 | 410 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1848 |
| 5 | 785000 | 2695 |
| 6 | 785000 | 3795 |
| 7 | 785000 | 5313 |
| 8 | 785000 | 7024 |
| 9 | 785000 | 9115 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 83

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Slot | 17.5 | 66% | 2 Door exhausts | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.20 | 71.97 | 1756 | 66.78% |
| S.D. | 0.66 | 1.19 | 477 | 2.60% |
| Max. | 23.55 | 74.39 | 3023 | 75.06% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.94 | 1.78 | 2.74 | 5.15 | 8.67 | 12.87 | 19.34 | 24.01 | 28.75 | 30.99 |
| Max. | 1.61 | 3.06 | 4.72 | 8.87 | 14.92 | 22.15 | 33.31 | 41.33 | 49.50 | 53.35 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.44 | 70.58 | 167 | 52.60% |
| S.D. | 0.81 | 1.46 | 42 | |
| Max. | 26.98 | 80.56 | 403 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.09 | 0.17 | 0.26 | 0.49 | 0.82 | 1.22 | 1.84 | 2.28 | 2.73 | 2.94 |
| Max. | 0.21 | 0.41 | 0.63 | 1.18 | 1.99 | 2.95 | 4.44 | 5.51 | 6.60 | 7.11 |

Histogram Distributions


Cage occupied zone average temperature (°C) distribution



Cage occupied zone average contamination (kg/kg) distribution



Cage occupied zone average relative humidity (%) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 418 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2303 |
| 5 | 785000 | 3876 |
| 6 | 785000 | 5752 |
| 7 | 785000 | 8650 |
| 8 | 785000 | 10734 |
| 9 | 785000 | 12856 |
| 10 | 785000 | 11384 |

Casename


Case 84

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low Ind | 17.5 | 66% | 2 Door exhausts | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.48 | 72.46 | 1853 | 60.88% |
| S.D. | 0.48 | 0.87 | 443 | 3.20% |
| Max. | 23.73 | 74.71 | 2964 | 66.31% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.96 | 1.88 | 2.89 | 4.17 | 5.86 | 8.13 | 11.12 | 15.00 | 19.93 | 26.05 |
| Max. | 1.54 | 3.00 | 4.62 | 6.67 | 9.37 | 13.00 | 17.79 | 24.00 | 31.87 | 41.66 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.48 | 70.67 | 152 | 52.33% |
| S.D. | 0.89 | 1.60 | 47 | |
| Max. | 26.19 | 79.14 | 380 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.08 | 0.15 | 0.24 | 0.34 | 0.48 | 0.67 | 0.91 | 1.23 | 1.64 | 2.14 |
| Max. | 0.20 | 0.38 | 0.59 | 0.85 | 1.20 | 1.67 | 2.28 | 3.07 | 4.08 | 5.34 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 85

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|---------------------|
| Radial | 17.5 | 66% | Low | 22 | 50% |
| Change Station | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation |
| ON alt design | Perp | Double | 2100 | 42000 gr | neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.37 | 72.27 | 1930 | 62.82% |
| S.D. | 0.31 | 0.57 | 425 | 2.86% |
| Max. | 23.02 | 73.44 | 2840 | 68.68% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 1.01 | 1.95 | 3.01 | 4.76 | 7.19 | 10.26 | 14.64 | 19.02 | 24.18 | 29.32 |
| Max. | 1.49 | 2.87 | 4.43 | 7.00 | 10.57 | 15.09 | 21.54 | 27.99 | 35.58 | 43.14 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.74 | 69.33 | 132 | 54.66% |
| S.D. | 0.36 | 0.65 | 53 | |
| Max. | 21.49 | 70.68 | 445 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.07 | 0.13 | 0.21 | 0.33 | 0.49 | 0.70 | 1.00 | 1.30 | 1.65 | 2.00 |
| Max. | 0.23 | 0.45 | 0.69 | 1.10 | 1.66 | 2.36 | 3.37 | 4.38 | 5.57 | 6.75 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 411 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1935 |
| 5 | 785000 | 2922 |
| 6 | 785000 | 4171 |
| 7 | 785000 | 5953 |
| 8 | 785000 | 7736 |
| 9 | 785000 | 9833 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 86

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|------------------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Slot | 17.5 | 66% | Low | 22 | 50% |
| Change Station ON alt design | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.30 | 72.13 | 1917 | 62.01% |
| S.D. | 0.45 | 0.81 | 554 | 3.29% |
| Max. | 23.25 | 73.84 | 3249 | 72.05% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 1.00 | 1.94 | 2.99 | 4.54 | 6.66 | 9.39 | 13.19 | 17.39 | 22.50 | 28.15 |
| Max. | 1.70 | 3.29 | 5.07 | 7.70 | 11.28 | 15.92 | 22.35 | 29.47 | 38.13 | 47.71 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.18 | 70.13 | 124 | 53.08% |
| S.D. | 0.44 | 0.79 | 67 | |
| Max. | 22.27 | 72.08 | 374 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.06 | 0.13 | 0.19 | 0.29 | 0.43 | 0.61 | 0.85 | 1.13 | 1.46 | 1.82 |
| Max. | 0.20 | 0.38 | 0.58 | 0.89 | 1.30 | 1.83 | 2.57 | 3.39 | 4.39 | 5.49 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 410 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1859 |
| 5 | 785000 | 2726 |
| 6 | 785000 | 3846 |
| 7 | 785000 | 5400 |
| 8 | 785000 | 7121 |
| 9 | 785000 | 9213 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution




Casename **Case 87**

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Radial | 19.2 | 59% | Low | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.65 | 72.77 | 1391 | 55.84% |
| S.D. | 4.31 | 7.76 | 455 | 3.11% |
| Max. | 24.56 | 76.21 | 2638 | 64.18% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.72 | 1.41 | 2.17 | 3.13 | 4.40 | 6.10 | 8.35 | 11.26 | 14.96 | 19.55 |
| Max. | 1.37 | 2.67 | 4.12 | 5.93 | 8.34 | 11.57 | 15.84 | 21.36 | 28.37 | 37.09 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.45 | 72.41 | 45 | 48.38% |
| S.D. | 0.39 | 0.71 | 17 | |
| Max. | 23.63 | 74.53 | 134 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.02 | 0.05 | 0.07 | 0.10 | 0.14 | 0.20 | 0.27 | 0.36 | 0.48 | 0.63 |
| Max. | 0.07 | 0.14 | 0.21 | 0.30 | 0.42 | 0.59 | 0.81 | 1.09 | 1.44 | 1.89 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution




Casename **Case 88**

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|---------------------|
| Slot | 19.2 | 59% | Low | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation |
| | On wall | Reduced | 700 | 14000 gr | neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 23.55 | 74.39 | 1550 | 56.31% |
| S.D. | 0.39 | 0.70 | 378 | 2.71% |
| Max. | 24.53 | 76.16 | 2516 | 63.30% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.81 | 1.57 | 2.42 | 3.49 | 4.90 | 6.80 | 9.30 | 12.55 | 16.67 | 21.78 |
| Max. | 1.31 | 2.55 | 3.93 | 5.66 | 7.96 | 11.04 | 15.10 | 20.37 | 27.06 | 35.37 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.56 | 72.61 | 48 | 48.07% |
| S.D. | 0.44 | 0.79 | 11 | |
| Max. | 23.62 | 74.52 | 86 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.02 | 0.05 | 0.07 | 0.11 | 0.15 | 0.21 | 0.29 | 0.39 | 0.51 | 0.67 |
| Max. | 0.04 | 0.09 | 0.13 | 0.19 | 0.27 | 0.38 | 0.51 | 0.69 | 0.92 | 1.21 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution

Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 89

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low Ind | 19.2 | 59% | Low | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 23.68 | 74.62 | 1636 | 56.53% |
| S.D. | 0.44 | 0.80 | 374 | 3.10% |
| Max. | 24.92 | 76.86 | 2599 | 63.57% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.85 | 1.66 | 2.55 | 3.68 | 5.17 | 7.17 | 9.82 | 13.25 | 17.59 | 23.00 |
| Max. | 1.35 | 2.63 | 4.05 | 5.85 | 8.22 | 11.40 | 15.60 | 21.04 | 27.95 | 36.53 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 22.92 | 73.26 | 62 | 47.10% |
| S.D. | 0.55 | 1.00 | 21 | |
| Max. | 24.09 | 75.36 | 217 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.03 | 0.06 | 0.10 | 0.14 | 0.20 | 0.27 | 0.37 | 0.50 | 0.67 | 0.87 |
| Max. | 0.11 | 0.22 | 0.34 | 0.49 | 0.69 | 0.95 | 1.30 | 1.75 | 2.33 | 3.04 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 90

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Radial | 18.8 | 61% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.93 | 71.47 | 1673 | 63.32% |
| S.D. | 0.29 | 0.52 | 385 | 2.63% |
| Max. | 22.36 | 72.24 | 2511 | 69.19% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.88 | 1.69 | 2.61 | 4.22 | 6.48 | 9.32 | 13.41 | 17.29 | 21.77 | 25.93 |
| Max. | 1.32 | 2.54 | 3.92 | 6.34 | 9.73 | 13.98 | 20.13 | 25.96 | 32.68 | 38.92 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.38 | 68.69 | 72 | 55.37% |
| S.D. | 0.23 | 0.41 | 29 | |
| Max. | 21.75 | 71.15 | 279 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.04 | 0.07 | 0.11 | 0.18 | 0.28 | 0.40 | 0.57 | 0.74 | 0.93 | 1.11 |
| Max. | 0.15 | 0.28 | 0.44 | 0.70 | 1.08 | 1.55 | 2.24 | 2.89 | 3.63 | 4.33 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 412 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1982 |
| 5 | 785000 | 3043 |
| 6 | 785000 | 4371 |
| 7 | 785000 | 6295 |
| 8 | 785000 | 8116 |
| 9 | 785000 | 10216 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 91

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Slot | 18.8 | 61% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.99 | 71.58 | 1709 | 63.38% |
| S.D. | 0.30 | 0.54 | 381 | 2.49% |
| Max. | 22.59 | 72.67 | 2643 | 69.86% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.90 | 1.73 | 2.67 | 4.33 | 6.65 | 9.57 | 13.79 | 17.76 | 22.33 | 26.55 |
| Max. | 1.39 | 2.68 | 4.12 | 6.69 | 10.29 | 14.79 | 21.32 | 27.47 | 34.54 | 41.07 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.46 | 68.83 | 57 | 54.97% |
| S.D. | 0.25 | 0.44 | 19 | |
| Max. | 21.66 | 70.99 | 183 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.03 | 0.06 | 0.09 | 0.14 | 0.22 | 0.32 | 0.46 | 0.59 | 0.75 | 0.89 |
| Max. | 0.10 | 0.19 | 0.29 | 0.46 | 0.71 | 1.03 | 1.48 | 1.90 | 2.39 | 2.85 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 412 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1987 |
| 5 | 785000 | 3056 |
| 6 | 785000 | 4394 |
| 7 | 785000 | 6333 |
| 8 | 785000 | 8158 |
| 9 | 785000 | 10259 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 92

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low Ind | 18.8 | 61% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.98 | 71.56 | 1631 | 62.80% |
| S.D. | 0.31 | 0.56 | 314 | 2.29% |
| Max. | 22.58 | 72.65 | 2404 | 69.73% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 0.86 | 1.65 | 2.55 | 4.02 | 6.06 | 8.65 | 12.33 | 16.04 | 20.39 | 24.75 |
| Max. | 1.26 | 2.43 | 3.75 | 5.92 | 8.93 | 12.74 | 18.18 | 23.63 | 30.06 | 36.48 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.40 | 68.71 | 41 | 55.05% |
| S.D. | 0.17 | 0.30 | 15 | |
| Max. | 20.95 | 69.70 | 151 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.02 | 0.04 | 0.06 | 0.10 | 0.15 | 0.22 | 0.31 | 0.41 | 0.52 | 0.63 |
| Max. | 0.08 | 0.15 | 0.24 | 0.37 | 0.56 | 0.80 | 1.14 | 1.48 | 1.88 | 2.29 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 411 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1933 |
| 5 | 785000 | 2916 |
| 6 | 785000 | 4161 |
| 7 | 785000 | 5936 |
| 8 | 785000 | 7716 |
| 9 | 785000 | 9814 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 93

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Radial | 17.5 | 66% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.94 | 71.49 | 1822 | 65.04% |
| S.D. | 0.37 | 0.66 | 402 | 2.43% |
| Max. | 22.66 | 72.79 | 2780 | 69.72% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.96 | 1.84 | 2.84 | 4.97 | 8.02 | 11.74 | 17.32 | 21.85 | 26.75 | 30.18 |
| Max. | 1.47 | 2.81 | 4.34 | 7.58 | 12.24 | 17.91 | 26.44 | 33.35 | 40.83 | 46.07 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.26 | 68.47 | 86 | 55.93% |
| S.D. | 0.52 | 0.94 | 399 | |
| Max. | 30.00 | 86.00 | 361 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.05 | 0.09 | 0.13 | 0.24 | 0.38 | 0.56 | 0.82 | 1.04 | 1.27 | 1.43 |
| Max. | 0.19 | 0.37 | 0.56 | 0.98 | 1.59 | 2.33 | 3.43 | 4.33 | 5.30 | 5.98 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 415 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2141 |
| 5 | 785000 | 3457 |
| 6 | 785000 | 5058 |
| 7 | 785000 | 7466 |
| 8 | 785000 | 9418 |
| 9 | 785000 | 11529 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 94

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Slot | 17.5 | 66% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.85 | 71.34 | 1757 | 64.38% |
| S.D. | 0.39 | 0.71 | 395 | 2.10% |
| Max. | 22.72 | 72.89 | 2734 | 69.23% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.93 | 1.78 | 2.74 | 4.66 | 7.38 | 10.73 | 15.71 | 19.97 | 24.68 | 28.40 |
| Max. | 1.44 | 2.77 | 4.27 | 7.24 | 11.49 | 16.70 | 24.44 | 31.06 | 38.40 | 44.18 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.23 | 68.41 | 117 | 56.34% |
| S.D. | 0.26 | 0.46 | 36 | |
| Max. | 20.69 | 69.24 | 328 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.06 | 0.12 | 0.18 | 0.31 | 0.49 | 0.71 | 1.04 | 1.33 | 1.64 | 1.89 |
| Max. | 0.17 | 0.33 | 0.51 | 0.87 | 1.38 | 2.01 | 2.94 | 3.73 | 4.61 | 5.31 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 414 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2080 |
| 5 | 785000 | 3299 |
| 6 | 785000 | 4795 |
| 7 | 785000 | 7017 |
| 8 | 785000 | 8919 |
| 9 | 785000 | 11026 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 95

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low Ind | 17.5 | 66% | Ceiling | 22 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.94 | 71.49 | 1822 | 64.10% |
| S.D. | 0.37 | 0.66 | 402 | 2.75% |
| Max. | 22.66 | 72.79 | 2780 | 70.20% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.96 | 1.84 | 2.84 | 4.77 | 7.50 | 10.87 | 15.84 | 20.21 | 25.09 | 29.12 |
| Max. | 1.47 | 2.81 | 4.34 | 7.28 | 11.44 | 16.59 | 24.18 | 30.84 | 38.30 | 44.45 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.23 | 68.42 | 69 | 55.88% |
| S.D. | 0.25 | 0.45 | 34 | |
| Max. | 20.79 | 69.42 | 281 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.04 | 0.07 | 0.11 | 0.18 | 0.29 | 0.41 | 0.60 | 0.77 | 0.96 | 1.11 |
| Max. | 0.15 | 0.28 | 0.44 | 0.74 | 1.16 | 1.68 | 2.44 | 3.12 | 3.87 | 4.49 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors (kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 414 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2054 |
| 5 | 785000 | 3231 |
| 6 | 785000 | 4684 |
| 7 | 785000 | 6827 |
| 8 | 785000 | 8708 |
| 9 | 785000 | 10814 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 96

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|---------------------|
| Radial | 17.5 | 66% | Ceiling | 22 | 50% |
| Change Station | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation |
| ON alt design | Perp all 5 on 1 wall | Double | 2100 | 42000 gr | neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.76 | 71.17 | 1957 | 65.79% |
| S.D. | 0.34 | 0.61 | 459 | 2.90% |
| Max. | 22.32 | 72.17 | 2763 | 71.27% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 1.04 | 1.98 | 3.05 | 5.51 | 9.06 | 13.35 | 19.87 | 24.88 | 30.15 | 33.32 |
| Max. | 1.47 | 2.80 | 4.31 | 7.78 | 12.80 | 18.85 | 28.06 | 35.12 | 42.57 | 47.05 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.01 | 68.02 | 100 | 56.95% |
| S.D. | 0.27 | 0.48 | 41 | |
| Max. | 20.70 | 69.26 | 280 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.05 | 0.10 | 0.16 | 0.28 | 0.46 | 0.68 | 1.01 | 1.27 | 1.54 | 1.70 |
| Max. | 0.15 | 0.28 | 0.44 | 0.79 | 1.30 | 1.91 | 2.85 | 3.56 | 4.32 | 4.77 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution



Cage occupied zone average contamination (kg/kg) distribution



Cage occupied zone average relative humidity (%) distribution

Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 417 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2210 |
| 5 | 785000 | 3636 |
| 6 | 785000 | 5355 |
| 7 | 785000 | 7972 |
| 8 | 785000 | 9981 |
| 9 | 785000 | 12097 |
| 10 | 785000 | 11384 |

Casename


Case 97

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|------------------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Slot | 17.5 | 66% | Ceiling | 22 | 50% |
| Change Station ON alt design | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH 15

Cage Condition Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.65 | 70.97 | 1725 | 64.22% |
| S.D. | 0.32 | 0.58 | 427 | 2.16% |
| Max. | 22.29 | 72.12 | 2885 | 69.99% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.91 | 1.75 | 2.69 | 4.54 | 7.16 | 10.39 | 15.18 | 19.33 | 23.96 | 27.70 |
| Max. | 1.52 | 2.92 | 4.50 | 7.59 | 11.98 | 17.39 | 25.38 | 32.33 | 40.07 | 46.34 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 20.02 | 68.03 | 111 | 57.04% |
| S.D. | 0.25 | 0.45 | 29 | |
| Max. | 20.78 | 69.40 | 294 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.06 | 0.11 | 0.17 | 0.29 | 0.46 | 0.67 | 0.98 | 1.25 | 1.54 | 1.79 |
| Max. | 0.15 | 0.30 | 0.46 | 0.77 | 1.22 | 1.77 | 2.59 | 3.29 | 4.08 | 4.72 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 414 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2065 |
| 5 | 785000 | 3259 |
| 6 | 785000 | 4730 |
| 7 | 785000 | 6907 |
| 8 | 785000 | 8796 |
| 9 | 785000 | 10902 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 98

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|------------------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Low ind | 17.5 | 66% | Ceiling | 22 | 50% |
| Change Station ON alt design | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |
| Perp all 5 on 1 wall | | Double | 2100 | 42000 gr | |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 21.70 | 71.07 | 1955 | 65.78% |
| S.D. | 0.30 | 0.54 | 428 | 3.05% |
| Max. | 22.30 | 72.13 | 2712 | 73.07% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 1.04 | 1.98 | 3.05 | 5.50 | 9.05 | 13.33 | 19.85 | 24.85 | 30.12 | 33.29 |
| Max. | 1.44 | 2.74 | 4.23 | 7.64 | 12.56 | 18.50 | 27.54 | 34.48 | 41.79 | 46.19 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|-------------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 19.99 | 67.98 | 83 | 56.88% |
| S.D. | 0.20 | 0.35 | 47 | |
| Max. | 20.65 | 69.17 | 334 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.04 | 0.08 | 0.13 | 0.23 | 0.39 | 0.57 | 0.85 | 1.06 | 1.29 | 1.42 |
| Max. | 0.18 | 0.34 | 0.52 | 0.94 | 1.54 | 2.28 | 3.39 | 4.24 | 5.14 | 5.68 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 417 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 2210 |
| 5 | 785000 | 3636 |
| 6 | 785000 | 5355 |
| 7 | 785000 | 7971 |
| 8 | 785000 | 9979 |
| 9 | 785000 | 12096 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 99

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Radial | 22 | 49% | Ceiling | 26 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 24.78 | 76.60 | 1984 | 58.69% |
| S.D. | 0.32 | 0.58 | 357 | 1.55% |
| Max. | 25.73 | 78.32 | 2959 | 61.50% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|-------|-------|-------|-------|-------|
| Mean | 1.03 | 2.01 | 3.10 | 4.46 | 6.28 | 8.70 | 11.91 | 16.07 | 21.34 | 27.89 |
| Max. | 1.54 | 3.00 | 4.62 | 6.66 | 9.36 | 12.98 | 17.76 | 23.96 | 31.82 | 41.60 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 23.86 | 74.94 | 27 | 44.18% |
| S.D. | 0.41 | 0.74 | 12 | |
| Max. | 24.70 | 76.46 | 123 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.01 | 0.03 | 0.04 | 0.06 | 0.09 | 0.12 | 0.16 | 0.22 | 0.29 | 0.38 |
| Max. | 0.06 | 0.12 | 0.19 | 0.28 | 0.39 | 0.54 | 0.74 | 1.00 | 1.33 | 1.73 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 100

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|----------------------|-----------------------------------|---------------------|------------------------|----------------------------|--------------------------------|
| Radial | 22 | 49% | Low | 25 | 50% |
| Change Station ON | Rack Orientation | Rack Density | Number of Mice in Room | Total mass of Mice in Room | Room Pressurisation neg 100cfm |

Room ACH
15

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 25.43 | 77.77 | 1730 | 55.39% |
| S.D. | 0.47 | 0.85 | 428 | 1.89% |
| Max. | 26.84 | 80.30 | 3305 | 60.49% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 0.90 | 1.75 | 2.70 | 3.89 | 5.47 | 7.59 | 10.38 | 14.01 | 18.61 | 24.32 |
| Max. | 1.72 | 3.35 | 5.16 | 7.43 | 10.46 | 14.50 | 19.84 | 26.77 | 35.55 | 46.47 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 24.82 | 76.67 | 40 | 41.72% |
| S.D. | 0.33 | 0.59 | 20 | |
| Max. | 25.82 | 78.47 | 192 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|------|
| Mean | 0.02 | 0.04 | 0.06 | 0.09 | 0.13 | 0.18 | 0.24 | 0.32 | 0.43 | 0.56 |
| Max. | 0.10 | 0.19 | 0.30 | 0.43 | 0.61 | 0.84 | 1.16 | 1.56 | 2.07 | 2.71 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution




Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution



Casename


Case 101

Description

| Supply Configuration | Supply Discharge Temperature (°C) | Supply Discharge RH | Exhaust Configuration | Exhaust Temperature (°C) | Exhaust RH |
|------------------------------|-----------------------------------|---------------------|-----------------------------|-------------------------------------|--------------------------------|
| Low Ind | 22 | 49% | Low | 25 | 50% |
| Change Station ON alt design | Rack Orientation Perp | Rack Density Double | Number of Mice in Room 1050 | Total mass of Mice in Room 21000 gr | Room Pressurisation neg 100cfm |

Room ACH
5

Cage Condition
Top On



Analysis Results

Cage Occupied Zone

| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 26.82 | 80.27 | 2400 | 55.39% |
| S.D. | 0.69 | 1.23 | 530 | 1.89% |
| Max. | 28.34 | 83.02 | 3522 | 60.49% |

Cage Occupied Zone NH₃ (ppm)

| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|-------|-------|-------|-------|-------|-------|
| Mean | 1.25 | 2.43 | 3.74 | 5.40 | 7.59 | 10.53 | 14.40 | 19.43 | 25.81 | 33.74 |
| Max. | 1.83 | 3.56 | 5.50 | 7.92 | 11.14 | 15.45 | 21.14 | 28.51 | 37.87 | 49.50 |

Room Breathing Zone


| | Temperature | | CO ₂ | RH |
|------|-------------|-------|-----------------|--------|
| | °C | °F | (ppm) | |
| Mean | 26.24 | 79.22 | 284 | 39.78% |
| S.D. | 1.52 | 2.74 | 138 | |
| Max. | 28.22 | 82.79 | 793 | |

Room Breathing Zone NH₃ (ppm)


| Day | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|------|------|------|------|------|------|------|------|------|-------|
| Mean | 0.15 | 0.29 | 0.44 | 0.64 | 0.90 | 1.25 | 1.71 | 2.30 | 3.06 | 4.00 |
| Max. | 0.41 | 0.80 | 1.24 | 1.78 | 2.51 | 3.48 | 4.76 | 6.42 | 8.53 | 11.15 |

Histogram Distributions

Cage occupied zone average temperature (°C) distribution



Cage occupied zone average contamination (kg/kg) distribution



Contamination conversion factors
(kg/kg - 7 ppm)

| Day | CO ₂ | NH ₃ |
|-----|-----------------|-----------------|
| 1 | 785000 | 408 |
| 2 | 785000 | 795 |
| 3 | 785000 | 1225 |
| 4 | 785000 | 1766 |
| 5 | 785000 | 2483 |
| 6 | 785000 | 3443 |
| 7 | 785000 | 4712 |
| 8 | 785000 | 6356 |
| 9 | 785000 | 8442 |
| 10 | 785000 | 11384 |

Cage occupied zone average relative humidity (%) distribution

